

REGULATIONS FOR PROPANE FIRE PITS

Propane fire pits must meet the requirements of ANSI Z21.58-1995 and be UL listed.

Installation must meet all clearance requirements for side and above clearance as a regular fire pit unless the appliance requires a greater clearance and have a zero clearance rating for the bottom.

Prior to installation of any such appliance, approval from the on site caretaker(s) must be obtained by use of the Construction Request process. The application must state the exact location of the planned appliance and one approved no other location may be utilized unless prior approval is obtained.

The application must contain the exact description of the proposed appliance and state the minimum clearance rating for the appliance as well as the standards that it meets. If a printed brochure is attached that includes the above information the actual information must be highlighted for easy locating by the caretaker(s).

The propane line supplying the appliance must be above ground the entire distance from the appliance to the tank.